
PanelMate® PLC Direct Communication Driver Manual

Preface

Information in this manual is subject to change without notice and does not represent a commitment on the part of Eaton's Cutler-Hammer, Inc. Permission is granted to duplicate this material without modification only for your use or the internal use of other members of your company or your agents to assist you in the use and servicing of products purchased from Eaton's Cutler-Hammer. No permission is granted to modify this material or include this material in a compilation.

RESTRICTED RIGHTS LEGEND

Use, duplication, or disclosure by the Government is subject to restrictions set forth in paragraph (b)(3)(B) of the Rights in Technical Data and Computer Software clause of DAR 7-104.9(a). Contractor/Manufacturer is Eaton Corporation's Cutler-Hammer Business Unit, 811 Green Crest Drive, Columbus, OH 43081.

TRADEMARKS

PanelMate is a federally registered trademark of Eaton Corporation. MS-DOS, Microsoft, and Windows are federally registered trademarks of Microsoft Corporation. Data Highway and Data Highway Plus are trademarks of Allen-Bradley. DeviceNet is a trademark of Open DeviceNet Vendor Association. Iomega is a federally registered trademark of Iomega Corporation.

Commercial brand names (trademarks) of products of manufacturers or developers, other than Eaton Corporation or its affiliates, that appear in this manual may be registered or unregistered trademarks of those respective manufacturers or developers, which have expressed neither approval nor disapproval of Cutler-Hammer® products and services.

©2002 Eaton Corporation. All rights reserved.

Printed in the United States of America.

P/N 01-00456-02

Support Services

The goal of Eaton's Cutler-Hammer business unit is to ensure your greatest possible satisfaction with the operation of our products. We are dedicated to providing fast, friendly and accurate assistance. That is why we offer you so many ways to get the support you need. Whether it's by phone, fax or mail, you can access Eaton's Cutler-Hammer support information 24 hours a day, seven days a week. Our wide range of services are listed below.

You should contact your local distributor for product pricing, availability, ordering, expediting and repairs.

Website Address www.cutler-hammer.eaton.com

Use the Cutler-Hammer website to find product information. You can also find information on local distributors or Cutler-Hammer sales offices.

e-TRC

Technical Resource Center
(support for OI, PLC & IPC)

VOICE:

- 800-809-2772, selection 5 (8:00AM-5:00PM EST)
- 414-449-7100, selection 5 (8:00AM-5:00PM EST)

FAX: 614-882-0417

EMAIL: CHATechSupport@eaton.com

AFTER-HOURS PLANT DOWN EMERGENCY:

- 800-809-2772, selection 5 (5:00PM-8:00AM EST)
- 414-449-7100, selection 5 (5:00PM-8:00AM EST)

If you are in the US or Canada, and have OI/PLC/IPC questions, you can take advantage of our toll-free line for technical assistance with hardware and software product selection, system design and installation, and system debugging and diagnostics. Technical support engineers are available for calls during regular business hours.

Information Fax-Back Service **VOICE: 614-899-5323**

The latest Cutler-Hammer product information, specifications, technical notes and company news are available to you via fax through this direct document request service. Using a touch-tone phone, you can select any of the info faxes from our automated product literature and technical document library, enter a fax number and receive the information immediately.

Repair and Upgrade Service
(support for OI & IPC)

VOICE:

- 800-809-2772, selection 5 (8:00AM-5:00PM EST)
- 414-449-7100, selection 5 (8:00AM-5:00PM EST)

FAX: 614-882-3414

EMAIL: RepairCHA@eaton.com

If you have questions regarding the repair or upgrade of an OI/IPC, contact your local distributor. Additional support is also available from our well-equipped Repair and Upgrade Service department.

European PanelMate Support Center

VOICE: +41 1 806 64 44 (9:00AM-5:00PM CET)


EMAIL: CHSupport@bfa.ch

This center, located in Zurich, Switzerland, provides high-level quality support and product repair services for your PanelMate products. You will receive real-time technical and application support.

Table of Contents

| | |
|--|-----------|
| Introduction..... | 4 |
| Introduction | 5 |
| Installing Drivers | 5 |
| Downloading Drivers to a PanelMate Unit..... | 6 |
| Serial Transfer Cables | 6 |
| Memory | 8 |
| Memory Ranges for DL430 Driver | 9 |
| Memory Ranges for DL440 Driver | 10 |
| Possible Configurations | 11 |
| Direct Connection..... | 12 |
| Multidrop Connection..... | 12 |
| Cabling..... | 13 |
| Communication between the Operator Station and the PLC Direct 405 Series PLCs..... | 14 |
| RS232 Cabling for PLC Direct 405 Series PLCs..... | 14 |
| RS422 Cabling for PLC Direct 405 Series PLCs..... | 14 |
| RS232 Cabling for PLC Direct 405 Series PLCs..... | 15 |
| RS422 Cabling for PLC Direct 405 Series PLCs..... | 15 |
| Communication Parameters | 16 |
| Serial Interface Port..... | 17 |
| PLC Direct 405 Series CPU | 17 |
| Serial Interface Port (Port 2) | 18 |
| Data Communication Module for the PLC Direct 405 Series | 20 |
| Bit Writes with Ladder Logic – PLC Direct 405 Series | 23 |
| PLC ID Field | 23 |
| Word and Bit References | 26 |
| Word Referencing Method | 27 |
| Word, Byte, and Bit References | 27 |
| Examples | 28 |
| Maintenance Access..... | 29 |
| Maintenance Access | 30 |
| PLC Cabling Cross-Reference List | 31 |
| PLC Cabling Cross-Reference List..... | 32 |
| Index..... | 33 |

Introduction



In this chapter, you will learn:

- *How to install driver software*
- *How to download drivers to a PanelMate unit*
- *The supported memory types*

Introduction

The Operator Station can be used with the programmable controllers in the PLC Direct 405 Series (DL430, DL440, and DL450,) using the PLC Direct driver. The driver takes responsibility for communications to the programmable controller, generating the protocol necessary to request information from, and send information to, the PLC. The PLC simply responds to these requests and commands. Ladder logic is required in the PLC to support bit writes to the PLC Direct 405 Series PLCs.

Connection to PLCs using the PLC Direct driver can be accomplished by a direct connection to the Serial Interface Port (port 2), on the PLC. The Serial Interface Port may be either RS232 RS422. The RS232 connection can only be used Point-to-Point. The RS422 connection has multi-drop capabilities.

Note: Check the Cutler-Hammer web site for current information on PanelMate PC connectivity to the PLC Direct driver.

Installing Drivers


PanelMate Configuration Editor software is installed using a CD-ROM. To install the drivers from the CD-ROM, select the **Install Software** option and then **Install Drivers**. From the dialog box, select the driver you wish to install.

Downloading Drivers to a PanelMate Unit

- In the VCP Transfer Utility, choose the “Executive” tab and select the proper Executive Firmware to download to the PanelMate unit.
- Click the button labeled “Add to Operation List.”
Note: In order to download to a PanelMate for the first time or to clear the existence of another driver, the PanelMate must first be loaded with Executive Firmware.
- Choose the “Driver” tab.
- Select the appropriate driver to be downloaded to the PanelMate.
- Click the button labeled “Add to Operation List.”
- Place the PanelMate unit in Serial Transfer Mode.
- Connect a serial transfer cable from the correct port on the PC to port 1 on the PanelMate. (See cabling below.)
- Click “Start” at the bottom of the VCP Transfer Utility window.
- **Note:** For a more detailed description of downloading procedures and troubleshooting see *PanelMate Power Series, PowerPro, Pro LT Transfer Utility User’s Guide*.


Serial Transfer Cables

Cable P/N 0518




Cable P/N 0818

(PanelMate Power Series 1500 and PanelMate 500 only)



RJ-11 pin configuration



Memory

The PLC Direct 405 Series driver supports the following memory types:

| Memory Type | Memory Address |
|--------------------|------------------|
| 16-Bit Word | |
| TMR | Timer |
| CNT | Counter |
| V | User Data |
| V | System Parameter |

| Memory Type | Memory Address |
|--------------------|----------------------------|
| Byte or Bit | |
| GX | Remote I/O |
| X | Input |
| Y | Output |
| C | Control Relays |
| S | Stages |
| T | Timer Relays (Read Only) |
| CT | Counter Relays (Read Only) |
| SP | Special Relays (Read Only) |

Memory Ranges for DL430 Driver

The following table shows the memory types and ranges supported by the DL430 driver.

| Memory Type | Discrete Memory Address | Word V Memory Addresses |
|--------------------|----------------------------|----------------------------|
| 16-Bit Word | | |
| Timer | TMR000-TMR177 | V0000-V00177 |
| Counter | CNT000-CNT177 | V01000-V01177 |
| User Data | | V01400-V07377 |
| System Param | | V07400-V07777 |

| Memory Type | Discrete Memory Address | Word V Memory Addresses |
|--------------------|----------------------------|----------------------------|
| Byte or Bit | | |
| Remote I/O | GX000-GX777 | V40000-V40037 |
| Inputs | X000-X477 | V40400-V40423 |
| Outputs | Y000-Y477 | V40500-V40523 |
| Control Relays | C000-C737 | V40600-V40635 |
| Stages | S000-S577 | V41000-V41027 |
| Timer Relays | T000-T177 (Read Only) | V41100-V41107 (Read Only) |
| Counter Relays | CT000-CT177 (Read Only) | V41140-V41147 (Read Only) |
| Special Relays | SP000-SP137 (Read Only) | V41200-V41205 (Read Only) |
| Special Relays | SP320-SP617 (Read Only) | V41215-V41230 (Read Only) |

Memory Ranges for DL440 Driver

The following Table shows the memory types and ranges supported by the DL440 driver.

| Memory Type | Discrete Memory Address | Word V Memory Addresses |
|--------------------|----------------------------|----------------------------|
| 16-Bit Word | | |
| Timer | TMR000-TMR377 | V0000-V00377 |
| Counter | CNT000-CNT177 | V01000-V01177 |
| User Data | | V01400-V07377 |
| | | V10000-V1777 |
| System Param | | V0700-V0737 |
| | | V07400-V07777 |

| Memory Type | Discrete Memory Address | Word V Memory Addresses |
|--------------------|----------------------------|----------------------------|
| Byte or Bit | | |
| Remote I/O | GX0000-GX1777 | V40000-V40077 |
| Inputs | X000-X477 | V40400-V40423 |
| Outputs | Y000-Y477 | V40500-V40523 |
| Control Relays | C0000-C1777 | V40600-V40677 |
| Stages | S0000-S1777 | V41000-V41077 |
| Timer Relays | T000-T377 (Read Only) | V41100-V41117 (Read Only) |
| Counter Relays | CT000-CT177 (Read Only) | V41140-V41147 (Read Only) |
| Special Relays | SP000-SP137 (Read Only) | V41200-V41205 (Read Only) |
| Special Relays | SP320-SP717 (Read Only) | V41215-V41234 (Read Only) |

Memory types supported by the DL450 are the same memory types supported by the DL440. Memory ranges for DL450 were not available at the time of printing of this manual. Consult the DL450 user manual for memory range information.

Possible Configurations


2

In this chapter, you will learn:

- *How to connect an operator station to PLC Direct 405 Series PLCs*


Direct Connection

Direct connection between one Operator Station and one PLC Direct 405 Series PLC.



Multidrop Connection

A Multidrop connection between one Operator Station and multiple PLC Direct 405 Series PLCs.



Cabling

3

In this chapter, you will learn:

- *The cabling requirements for PLC Direct 405 Series PLCs*


Communication between the Operator Station and the PLC Direct 405 Series PLCs

Communications between the Operator Station and PLC Direct 405 Series PLCs can be achieved via RS232 or RS422. The maximum cable length when using RS232 is 50 feet, while the maximum cable length for RS422 is 4000 feet. RS422 cable must be a twisted double-wire shielded cable.

A 15-foot PLC cable can be purchased from Cutler-Hammer. Contact the Customer Support Group (see the Customer Support section in the Preface,) or your local distributor for more information. Refer to the PLC Cabling Cross-Reference List section for cabling catalog numbers.


RS232 Cabling for PLC Direct 405 Series PLCs

The Operator Stations that have 9-pin female connectors (DP-9S) must have cables configured male connectors (DB-9P).




Note: Additional Pins are not recommended for RS232 communication to the PLC Direct 405 Series.

RS422 Cabling for PLC Direct 405 Series PLCs




RS232 Cabling for PLC Direct 405 Series PLCs

The Operator Stations that have RJ-11 6-wire and RJ 45 modular jacks must have cables configured with modular connections.




Note: Additional pins are not recommended for RS232 communication to the PLC Direct 435 Series.

RS422 Cabling for PLC Direct 405 Series PLCs



Communication Parameters




In this chapter, you will learn:

- *The different switch settings*

Serial Interface Port

PLC Direct 405 Series CPU

The Serial Interface port (port 2) enables the PLC Direct 405 Series to interface directly to the Operator Station.



Note: The Operator Station does not support communications with the Programmer Port (port 1).

Serial Interface Port (Port 2)

The following table shows the pinouts for the Serial Interface Port (port 2).

| Pin | Name | Pin | Name |
|-----|------------------|-----|--------------|
| 1 | Not Used | 14 | TXD+ (RS422) |
| 2 | TXD (RS232) | 15 | Not Used |
| 3 | RXD (RS232) | 16 | TXD- (RS422) |
| 4 | RTS (RS232) | 17 | Not Used |
| 5 | CTS (RS232) | 18 | RTS- (RS422) |
| 6 | Not Used | 19 | RTS+ (RS422) |
| 7 | SG (RS232/RS422) | 20 | Not Used |
| 8 | Not Used | 21 | Not Used |
| 9 | RXD+ (RS422) | 22 | Not Used |
| 10 | RXD- (RS422) | 23 | CTS- (RS422) |
| 11 | CTS+ (RS422) | 24 | Not Used |
| 12 | Not Used | 25 | Not Used |
| 13 | Not Used | | |

Communication to the PLC Direct 405 Series is through the DirectNET Protocol in Master/Slave mode. The Operator Station uses hexadecimal data protocol, not ASCII. Note that the data protocol and parity are set with the PLC Direct programming software. Standard communication parameters for communicating directly with the PLC Direct 405 Series Serial Interface Port are shown below.

RS232 or RS422

8 Data Bits

1 Stop Bit

Odd Parity

19200 Baud Rate*

* The Baud is dipswitch selectable.

Dipswitch Settings

The dipswitch block is located at the rear of the CPU. The table below summarizes the dipswitch settings for the CPU dipswitch.

| Switch | ON | OFF |
|--------|---|---|
| SW1 | CPU battery disabled. | CPU battery enabled |
| SW2 | Station Address is 1 | Station address is set via MIU (Machine Interface Unit) or programming software |
| SW3 | Baud rate selection for Serial Interface Port | |
| SW4 | Baud rate selection for Serial Interface Port | |

Dipswitch Settings for Baud Rate

SW3 and SW4 on the dipswitch control the baud rate at which the Serial Interface Port will operate. Refer to the table below for the baud rates corresponding to the settings of SW3 and SW4.


| Baud | SW3 | SW4 |
|-------|-----|-----|
| 300 | Off | Off |
| 1200 | Off | On |
| 9600 | On | Off |
| 19200 | On | On |

Data Communication Module for the PLC Direct 405 Series

The Data Communication Module (DCM) enables the PLC Direct 405 Series to interface with the Operator Station. The DCM supports the DirectNET protocol either Master/Slave or Peer-to-Peer. In the Master/Slave configuration, the Operator Station will be the Master device and the DCM will be the slave device in both the Point-to-Point and the Multidrop configurations. The DCM has a serial connection that will connect to the multi-drop network or directly point-to-point to the Operator Station.


Switch Locations

The figure below shows the switch locations.



Dipswitch 1

There are two rotary switches on the DCM that select the network address of the PLC. This address must match the assigned PLC ID in the PLC Name and Port Table. There are two dipswitches located on the DCM. Dipswitch 1 sets the communication parameters. Switches 1, 2, and 3 of dipswitch 1 select the baud rate. Switch 4 sets the parity. Switch 5 must be set to OFF. Switches 6 through 8 set the Response Time Delay. This should be set to 0ms.




Dipswitch 2.

Dipswitch 2 sets the communication protocol and communication functions. Switch 1 and 2 select the protocol to be used. The following table shows the valid switch setting for the Operator Station Interface.

| Operator Station Port | Protocol | Switch 1 | Switch 2 |
|-----------------------|-----------------|----------|----------|
| DirectNET/M | DirectNET Slave | OFF | OFF |
| DirectNET/P | DirectNET P/P | ON | OFF |

Switch 3 and 4 of dipswitch 2 should be set to OFF to enable communication timeout and to allow data to be transmitted in hexadecimal.



The following parameters are the default port characteristics of the DCM.

RS422

8 Data Bits

1 Stop Bit

Odd Parity

Baud Rate 9600

Master-Slave

Bit Writes with Ladder Logic – PLC Direct 405 Series

The DirectNET protocol does not permit an external intelligent device to directly alter the state of a single bit without over-writing the entire byte in which that bit exists. As a result, the Operator Station will write values to designated registers in the PLC, specifying which bit should be set or cleared. It is necessary to write a section of Ladder Logic/Stage Programming to interpret this value in order to change the appropriate bit. The Operator Station will write to four V memory registers to set or reset a bit. The four registers will be consecutive starting with the Bit Write register entered in the PLC ID field. If a Bit Write register is not entered, the register will default to V7374. When the default register is used, V7374, V7375, V7376 and V7377 will be used to accomplish the Bit Writes.

- Register 1 This register contains a 16-bit mask in which the bit position to be set will be set to 1 and all other bits will be set to 0.
- Register 2 Each memory type has a corresponding V memory address. Register 2 contains the V memory address in which the bit to be set is located.
- Register 3 This register contains a 16-bit mask in which the bit position to be reset will be set to 0 and all other bits will be set to 1.
- Register 4 This register contains the V memory address in which the bit to be reset is located.

PLC ID Field (Remote ID in the PLC and Port Name Table)

The format for the PLC ID for PLC Direct 405 Series will include both the PLC ID and a memory register used for the four Bit Write Registers. The format will be the PLC ID followed by the memory address.

XX-VYYYYY or XX-YYYYY or XX

Where

- XX PLC ID in range 1 - 90
- PLC ID/memory address separator
- V Optional memory type specifier
- YYYYY Optional starting with V memory address in range 1400 -7374

If a memory address is not entered, the Bit Write register will default to V7374. The following ladder logic rungs may be added to a PLC Direct 405 Series program for the purpose of setting and clearing individual bits.

```

|      IF SET MASK IS PRESENT, LOAD ACCUMULATOR WITH TARGET WORD
|      VALUE, PERFORM LOGICAL OR WITH MASK IN V7374 AND RETURN
|      TARGET WORD VALUE.
|
|CONTAINS                                LD-----+
|BIT MASK                                | CONTAINS |
|FOR SET                                | V ADDRESS |
|      V7374 KO                          | TO CHANGE |
|-----] <> -----P7375-----+
|
|                                          |
|                                          |OR-----|
|                                          || CONTAINS |
|                                          || BIT MASK |
|                                          || FOR SET  |
|                                          |-----V7374-----|
|                                          |
|                                          |OUT-----|
|                                          || CONTAINS |
|                                          || V ADDRESS |
|                                          || TO CHANGE |
|                                          ++-----P7375-----|
|
|      IF RESET MASK IS PRESENT, LOAD ACCUMULATOR WITH TARGET WORD
|      VALUE, PERFORM LOGICAL AND WITH VALUE IN V7376 AND RETURN
|      TARGET WORD VALUE.
|
|CONTAINS                                LD-----|
|BIT MASK                                | CONTAINS |
|FOR RESET                              | V ADDRESS |
|      V7376 KO                          | TO CHANGE |
|-----] <> -----P7377-----|
|
|                                          |
|                                          |AND-----|
|                                          || CONTAINS |
|                                          || BIT MASK |
|                                          || FOR RESET |
|                                          |-----V7376-----|
|                                          |
|                                          |OUT-----+
|                                          || CONTAINS |
|                                          || V ADDRESS |
|                                          || TO CHANGE |
|                                          ++-----P7377-----|
|


```

```

|CONTAINS                                LDD-----|
|BIT MASK                                |          |
|FOR SET                                |          |
|      V7374  KO                        |          |
|-----] <> [-----|-----KO-----|
|
|CONTAINS                                |          |
|BIT MASK                                |          |
|FOR RESET                              |          |
|      V7376  KO                        |          |
|-----] <> [-----|
|
|          CLEAR OUT DATA FROM SET BIT FUNCTION
|
|CONTAINS                                OUTD-----|
|BIT MASK                                |  CONTAINS  |
|FOR SET                                |  BIT MASK  |
|      V7374  KO                        |  FOR SET   |
|-----] <> [-----|-----V7374-----|
|
|          CLEAR OUT DATA FROM RESET FUNCTION
|
|CONTAINS                                OUTD-----|
|BIT MASK                                |  CONTAINS  |
|FOR RESET                              |  BIT MASK  |
|      V7376  KO                        |  FOR RESET |
|-----] <> [-----|-----V7376-----|
|
|
|
|
|-----] ( END )

```

Word and Bit References



In this chapter, you will learn:

- *How to configure word and bit references*

Word Referencing Method

The general word referencing method is:

[plcname,word#format]

The "plcname" is the name of the designated PLC as listed in the PLC Name and Port Table. The "word" is the reference number (address) of the word or register to be read or written. The "#format" is a code which specifies the format of the data being read or written. The "plcname" and "#format" are optional.

The general bit referencing method is:

[plcname,bit]

The "plcname" is the designated PLC as listed in the PLC Name and Port Table. The "bit" is the reference number (address) of the bit, coil, or input to be written or read.

See the "Word and Bit References" topic in the Configuration Software Online Help for a more detailed explanation of word and bit references, including format descriptions.

Word, Byte, and Bit References

PLC Direct 405 Series PLCs use octal word addresses. The Operator Station format default is U16.

The following is the format for a register reference.

[XY]

| | |
|---|--|
| X | Memory type (TMR, CNT, and V) |
| Y | Word address (leading zeroes not required) |

To reference a byte value, the memory address must be on an 8-bit boundary. The following is the format for an 8-bit (byte) reference.

[B:XY]

| | |
|---|---|
| B | Designating byte reference |
| : | Byte designator/byte address separator |
| X | Memory type (GX, X, Y, C, S, T, CT, and SP) |
| Y | Byte Address |

The following is the format for a bit reference within a word.

[XY/B]

| | |
|---|--|
| X | Memory type [TMR, CNT, and V] |
| Y | Word address (leading zeroes not required) |
| B | Bit number in the range (0 – 17 in octal) |

The following is the format for a single bit reference (device).

[XY]

| | |
|---|---|
| X | memory type (GX, X, Y, C, S, T, CT, and SP) |
| Y | Bit address (leading zeroes not required) |

Examples


The following are examples of valid PLC references that may be assigned in the Operator Station expression fields.

| Word References | |
|-----------------|-----------------------|
| Reference | Description |
| [TMR11] | Timer register 12 |
| [CNT30] | Counter register 30 |
| [V24] | User Data register 22 |

| Byte References | |
|-----------------|----------------------------|
| Reference | Description |
| [B:GX10] | Remote I/O register 10 |
| [B:X20] | Input register 20 |
| [B:Y100] | Output register 100 |
| [B:C30] | Control relay register 30 |
| [B:S40] | Stage register 40 |
| [B:T50] | Timer relay register 50 |
| [B:CT170] | Counter relay register 170 |
| [B:SP0] | Special relay register 0 |

| Bit References | |
|----------------|-----------------------------|
| Reference | Description |
| [GX12] | Bit 12 of remote I/O memory |
| [X315] | Bit 315 of input memory |
| [CNT.50/10] | Bit 10 of counter word 150 |

Maintenance Access



In this chapter, you will learn:

- *How to use the Maintenance Template*

Maintenance Access

The Maintenance Template will access all memory locations supported by the PLC driver as defined in this manual. When running online, you may change the PLC reference. The Maintenance Template is designed to assist you in specifying the PLC reference by scrolling through a list of mnemonics that are used to enter the PLC word reference. When online in the PLC reference change mode, the following list is available.


“TMR”, “CNT”, “V”, “GX”, “X”, “Y”, “C”, “S”, “T”, “CT”, “SP”, “B:”, and “/”

You must enter the correct mnemonics and numeric values and create a legal reference to change a PLC reference.

Note: When a new reference is entered on an Operator Station, the Maintenance Template will remain in a paused state until the **Start Monitor** control button or the **Chng** soft function key is pressed. When the **Start Monitor** control button or the **Chng** soft function key is pressed, the Operator Station will parse the reference. (Parsing means checking the syntax and range of the reference to ensure that it is supported by the driver.) If correct, the template begins updating.

Note: A Maintenance Template cannot be used to monitor unsolicited references.

PLC Cabling Cross-Reference List



In this chapter, you will learn:

- *The catalog numbers for PLC cables*

PLC Cabling Cross-Reference List

If you have a PanelMate Power Series 1500 and you wish to order PLC cables from Cutler-Hammer, use the following catalog numbers:

| | |
|------|---|
| TI32 | PLC direct and TI 405 Series cable (RS232C) |
| TI34 | PLC Direct and TI 435 Series cable (RS422) |

For all other PanelMate Power Series models, use the following catalog numbers:

| | |
|-------|---|
| TI22 | PLC direct and TI 405 Series cable (RS232C) |
| TI24A | PLC direct and TI 435 Series cable (RS422) |

Index

D

Direct Connection, 12
Downloading Drivers to a PanelMate Unit, 6

E

Examples, 28

I

Installing Drivers, 5
Introduction, 5

M

Maintenance Access, 30
Memory Ranges, 9
 DL430 Driver, 9
 DL440 Driver, 10
Memory Types, 8

O

Operator Station and the PLC Direct PLCs Communication,
14

P

PLC Cabling Cross-Reference List, 32
PLC Direct 405 Series
 Bit Writes with Ladder Logic, 23
 CPU, 17
 Data Communication Module, 20
 PLC ID Field, 23
 RS232 Cabling, 14, 15
 RS422 Cabling, 14, 15
 Word Referencing Methods, 27
 Word, Byte, and Bit References, 27

R

RS232 Cabling, 14, 15
RS422 Cabling, 14, 15

S

Serial Interface Port, 17
Serial Transfer Cables, 6

Reader Comment Card

Cutler-Hammer strives to provide quality user guides and product manuals. Please take a moment to fill out this comment card.

Title: PLC Direct Communication Driver Manual 01-00456-02

| | Excellent | Good | Fair | Poor |
|--|--------------------------|--------------------------|--------------------------|--------------------------|
| Is the document easy to follow? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Does the product work as described in this document? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Are the instructions easy to follow? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Are the examples helpful/useful? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Are there enough examples? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Is the document organized logically? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Is it easy to find what you are looking for? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Are the illustrations clear and useful? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

How would you improve this document?

Please list any errors found in this document:

Other comments:

Your name and address: (optional)

Thank you for your comments. Please fax this page to:

Cutler-Hammer Technical Publications Dept.

FAX : 614-882-0417